
	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 17th June 2024

Table: Average water quality for Kampala Water during the period running 10th June - 16th June 2024

Parameter	National Standard For Potable Water	Monitoring Points								
		Busabala Road Clinic	Wankulukuku Kabowa	Portbell Market	Nakinyuguzi Parents School	Bwaise Industrial Area	Kanyanya Police Post	Kisenyi I Musajjalumbwa Road	Bandwe Trading Center	Kireka Market
Electrical Conductivity (µs/cm)	≤1500	151	154	158	163	159	158	161	161	154
pH	6.5-8.5	7.0	7.1	6.9	7.0	6.8	7.1	6.9	6.7	6.8
Turbidity (NTU)	≤5	0.83	0.90	0.83	0.89	0.67	0.72	0.82	0.81	0.42
Colour – Apparent (PtCo)	≤15	9	10	8	7	7	8	8	5	5
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.20	0.40	0.35	0.40	0.30	0.40	0.30	0.40	0.40
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0

Remarks

The physio-chemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water.





Denis Smith Akejo
Senior Quality Control Officer – KW

Written by:



Enos Malambala
Quality Assurance Manager – KW

Approved by:

	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 17th June 2024

Table: Average water quality for Kampala Water during the period running 10th June - 16th June 2024

Parameter	National Standard For Potable Water	Monitoring Points							
		Sonde Village	Goma Misindye Zone	Naalya Estate	Mukono Kyetume	Nsambya Hospital	Ggaba Market	Makindye Washing Bay	Kiswa Health Center
Electrical Conductivity (µs/cm)	≤1500	106	106	126	104	164	168	159	157
pH	6.5-8.5	7.3	7.3	7.2	7.3	6.9	7.3	7.2	6.9
Turbidity (NTU)	≤5	0.62	0.46	0.44	0.60	0.72	0.50	0.60	0.59
Colour – Apparent (PtCo)	≤15	8	7	5	5	8	4	6	6
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.30	0.30	0.30	0.40	0.40	0.20	0.40	0.40
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0

Remarks

The physio-chemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water.



Denis Smith Akejo
Senior Quality Control Officer – KW

Written by:



Enos Malambala
Quality Assurance Manager – KW

Approved by: