
	<b>National Water and Sewerage Corporation</b> Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 <sup>th</sup> March 2019	Website Report	Version No.: 1	Revision date:

**Report Date:** 01<sup>st</sup> July 2024

**Table: Average water quality for Kampala Water during the period running 24<sup>th</sup> June - 30<sup>th</sup> June 2024**

Parameter	National Standard For Potable Water	Monitoring Points								
		Kikokiro Village	Katale Mayanja	Ericcson House Nakasero	Kalerwe Market Upper Wing	Kasode Market	Butabika SV	Bweyogerere Kazinga Zone	Naguru Police Barracks	Bulaga Police Post
Electrical Conductivity (µs/cm)	≤1500	164	157	156	157	156	110	110	159	142
pH	6.5-8.5	6.6	7.2	7.2	7.1	7.0	7.3	7.3	6.9	7.0
Turbidity (NTU)	≤5	0.53	0.48	0.50	0.51	0.49	0.40	0.40	0.99	0.45
Colour – Apparent (PtCo)	≤15	3	2	2	3	2	4	4	10	5
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.25	0.30	0.40	0.30	0.30	0.30	0.30	0.40	0.40
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0

**Remarks**

The physio-chemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water.





Denis Smith Akejo  
**Senior Quality Control Officer – KW**

Written by:



Enos Malambala  
**Quality Assurance Manager – KW**

Approved by:

	<b>National Water and Sewerage Corporation</b> Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 <sup>th</sup> March 2019	Website Report	Version No.: 1	Revision date:

**Report Date:** 01<sup>st</sup> July 2024

**Table: Average water quality for Kampala Water during the period running 24<sup>th</sup> June - 30<sup>th</sup> June 2024**

Parameter	National Standard For Potable Water	Monitoring Points							
		Buloba Kiwumu Trading Center	Bulenga Trading Center	Buddo Trading Center	Emma Oils - Nsangi	Maya Nanziga Trading Center	Seeta Market	Bukerere Trading Center	Mukono Nama Trading Center
Electrical Conductivity ( $\mu\text{s}/\text{cm}$ )	$\leq 1500$	143	152	146	153	153	108	108	109
pH	6.5-8.5	7.1	7.4	6.9	7.5	7.0	7.4	7.3	7.3
Turbidity (NTU)	$\leq 5$	0.51	0.67	0.82	0.51	0.58	0.44	0.30	0.67
Colour – Apparent (PtCo)	$\leq 15$	4	8	7	4	6	2	0	5
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.40	0.40	0.30	0.30	0.30	0.30	0.40	0.30
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0

**Remarks**

The physio-chemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water.



Denis Smith Akejo  
**Senior Quality Control Officer – KW**

Written by:



Enos Malambala  
**Quality Assurance Manager – KW**

Approved by: