
	<b>National Water and Sewerage Corporation</b> Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 <sup>th</sup> March 2019	Website Report	Version No.: 1	Revision date:

**Report Date:** 03<sup>rd</sup> June 2024

**Table: Average water quality for Kampala Water during the period running 27<sup>th</sup> May - 02<sup>nd</sup> June 2024**

Parameter	National Standard For Potable Water	Monitoring Points								
		Bugolobi Market	Butabika Hospital	Kireka Kabaka's Palace	Lugogo Bypass	Namuwongo Godown	Ovino Shopping Mall Kisenyi	Bunga market	Kansanga Market	Munyonyo Market
Electrical Conductivity (µs/cm)	≤1500	151	107	160	159	161	161	152	157	159
pH	6.5-8.5	6.9	7.4	7.0	7.0	6.8	6.9	7.0	6.9	6.9
Turbidity (NTU)	≤5	0.62	0.55	0.48	0.58	0.28	0.22	0.81	0.82	0.91
Colour – Apparent (PtCo)	≤15	6	6	5	6	2	1	10	8	10
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.30	0.30	0.40	0.30	0.40	0.30	0.40	0.30	0.45
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0

**Remarks**

The physio-chemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water.





Denis Smith Akejo  
**Senior Quality Control Officer – KW**

Written by:



Enos Malambala  
**Quality Assurance Manager – KW**

Approved by:

	<b>National Water and Sewerage Corporation</b> Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 <sup>th</sup> March 2019	Website Report	Version No.: 1	Revision date:

**Report Date:** 03<sup>rd</sup> June 2024

**Table:** Average water quality for Kampala Water during the period running 27<sup>th</sup> May - 02<sup>nd</sup> June 2024

Parameter	National Standard For Potable Water	Monitoring Points							
		Busabala - Kirinda C	Kabuuma Village Busabala	Hotel Africana	Buganda Royal Institute	Makerere College School	Hill View Estates Sonde	Bwaise Mayinja Zone	Nsambya Sisters
Electrical Conductivity (µs/cm)	≤1500	160	150	166	166	167	157	158	159
pH	6.5-8.5	6.7	7.1	7.0	7.1	7.1	6.9	6.8	6.7
Turbidity (NTU)	≤5	0.34	0.98	0.43	0.62	0.69	0.57	0.57	0.53
Colour – Apparent (PtCo)	≤15	1	10	3	5	8	6	4	3
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.25	0.40	0.30	0.30	0.40	0.45	0.40	0.30
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0

**Remarks**

The physio-chemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water.



Denis Smith Akejo  
**Senior Quality Control Officer – KW**

Written by:



Enos Malambala  
**Quality Assurance Manager – KW**

Approved by: