
	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 21st August 2024

Table: Average water quality for Kampala Water during the period running 12th August – 18th August 2024

Parameter	National Standard For Potable Water	Monitoring Points								
		Bandwe Trading Center	Nansana Nabweru Road	Zana Market	AM Luzira Water Village Quarters	Kalinabiri Ntinda	Mukono Dandira	Bwaise Kusatu zone	Uganda Management Institute	Matuga Trading Center
Electrical Conductivity (µs/cm)	≤1500	178	161	161	172	140	127	160	161	164
pH	6.5-8.5	7.1	6.6	7.3	6.9	7.0	7.4	6.8	7.0	6.8
Turbidity (NTU)	≤5	1.64	0.24	0.83	0.55	0.58	0.61	0.67	0.78	0.51
Colour – Apparent (PtCo)	NS	10	2	8	6	10	7	4	5	6
Colour – True (TCU)	≤15	0	0	0	0	0	0	0	0	0
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.20	0.30	0.30	0.40	0.35	0.45	0.20	0.40	0.20
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0

Remarks

The physio-chemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water.

Wanyera Julius



Wanyera Julius
Ag.Senior Quality Control Officer – KW

Written by:

Enos Malambala

Enos Malambala
Quality Assurance Manager – KW

Approved by:

	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 01st July 2024

Table: Average water quality for Kampala Water during the period running 24th June – 30th June 2024

Parameter	National Standard For Potable Water	Monitoring Points							
		Buloba Kiwumu Trading Center	Bulenga Trading Center	Buddo Trading Center	Emma Oils - Nsangi	Maya Nanziga Trading Center	Seeta Market	Bukerere Trading Center	Mukono Nama Trading Center
Electrical Conductivity ($\mu\text{s}/\text{cm}$)	≤ 1500	143	152	146	153	153	108	108	109
pH	6.5-8.5	7.1	7.4	6.9	7.5	7.0	7.4	7.3	7.3
Turbidity (NTU)	≤ 5	0.51	0.67	0.82	0.51	0.58	0.44	0.30	0.67
Colour – Apparent (PtCo)	NS	4	8	7	4	6	2	0	5
Colour – True (TCU)	≤ 15	0	0	0	0	0	0	0	0
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.40	0.40	0.30	0.30	0.30	0.30	0.40	0.30
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0

Remarks

The physio-chemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water.



Denis Smith Akejo
Senior Quality Control Officer – KW

Written by:



Enos Malambala
Quality Assurance Manager – KW

Approved by: