
	<b>National Water and Sewerage Corporation</b> Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 <sup>th</sup> March 2019	Website Report	Version No.: 1	Revision date:

**Report Date: 09<sup>st</sup> September 2024**

**Table: Average water quality for Kampala Water during the period running 02<sup>nd</sup> September - 08<sup>st</sup> September 2024**

Parameter	National Standard For Potable Water	Monitoring Points								
		Mukono Market	Mbuya Comboni Sisters	Buwate Community	Fairway Hotel	Kairos Schools Bukasa	Kawempe Booster	Munyonyo Market	Namusera Trading Center	Katwe Market
Electrical Conductivity (µs/cm)	≤1500	111	158	136	150	170	170	158	156	164
pH	6.5-8.5	7.3	6.7	7.2	6.6	7.4	7.5	7.1	7.2	7.6
Turbidity (NTU)	≤5	0.46	0.41	0.45	0.48	0.16	0.12	0.59	1.13	0.29
Colour – Apparent (PtCo)	NS	5	4	6	8	0	0	5	13	9
Colour - True (TCU)	≤15	0	0	0	0	0	0	0	0	0
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0
Residual Free Chlorine (mg/L)	0.20-0.50	0.50	0.40	0.30	0.40	0.4	0.40	0.40	0.30	0.40
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0

**Remarks**

The physio-chemical and bacteriological quality of the water supplied in the Network distribution complied with the National Standards for treated potable water.

*Wanyera Julius*

Wanyera Julius  
**Ag.Senior Quality Control Officer – KW**

Written by:

*Enos Malambala*

Enos Malambala  
**Quality Assurance Manager – KW**

Approved by: