
	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 21st October 2024

Table: Average water quality for Kampala Water during the period running 14th October - 20th October 2024

Parameter	National Standard For Potable Water	Monitoring Points									
		Kasubi Market	Mengo Kisenyi, Nanyonzi Zone	Rubaga Kabusu	Bakuli Market	Cooper Complex	Kireka Market	Kalinabiri Ntinda	Busabala Road, Kibiri TC	Ndejje Ziranumbi	Rubaga Cathedral Diocesan Office
Electrical Conductivity (µs/cm)	≤1500	156	155	155	155	154	150	111	152	153	153
pH	6.5-8.5	6.5	6.5	6.5	6.5	6.5	7.2	6.8	7.2	7.2	7.2
Turbidity (NTU)	≤5	0.36	0.32	0.31	0.34	0.30	0.62	0.43	0.73	0.50	0.51
Colour – Apparent (PtCo)	≤15	2	1	2	2	1	5	3	4	5	5
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.30	0.30	0.30	0.40	0.30	0.40	0.40	0.25	0.25	0.40
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physio-chemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water.





Denis Smith Akejo
Principal Quality Control Officer – KW

Written by:



Enos Malambala
Quality Assurance Manager – KW

Approved by:

	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 21st October 2024

Table: Average water quality for Kampala Water during the period running 14th October - 20th October 2024

Parameter	National Standard For Potable Water	Monitoring Points									
		Lyna Nursery School	Mawanda Road - Denaro Apartment	Katale Mayanja	Bulaga Police Post	Buloba Kiwumu Trading Center	Maya Trading Center	Bunga market	Kansanga Market	Mukono UCU	Namamve Booster
Electrical Conductivity ($\mu\text{s}/\text{cm}$)	≤ 1500	152	151	149	149	153	320	150	153	132	123
pH	6.5-8.5	7.0	7.1	6.8	7.1	7.0	7.2	7.0	6.7	6.6	6.8
Turbidity (NTU)	≤ 5	0.58	0.58	0.28	0.51	0.26	0.78	0.18	0.55	0.60	0.75
Colour – Apparent (PtCo)	≤ 15	6	6	3	6	0	7	0	2	6	7
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.40	0.40	0.40	0.30	0.30	0.35	0.30	0.40	0.45	0.40
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physio-chemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water.



Denis Smith Akejo
Principal Quality Control Officer – KW

Written by:



Enos Malambala
Quality Assurance Manager – KW

Approved by: