
	<b>National Water and Sewerage Corporation</b> Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 <sup>th</sup> March 2019	Website Report	Version No.: 1	Revision date:

**Report Date:** 23<sup>rd</sup> September 2024

**Table:** Average water quality for Kampala Water during the period running 16<sup>th</sup> September - 22<sup>nd</sup> September 2024

Parameter	National Standard For Potable Water	Monitoring Points									
		Aqua Coolers Ltd - 7th Street	City Abattoir	Rubaga Kabusu	Kabalega Crescent - Luzira	Kireka SDA P/S	Kijabijjo Trading Center	Ntinda Old Market	Kulambiro Pal & Lisa School	Kamwokya Community	Kyebando Ring Road SV
Electrical Conductivity (µs/cm)	≤1500	169	169	168	166	169	125	144	143	160	170
pH	6.5-8.5	7.0	7.4	7.5	7.1	7.1	7.3	7.2	7.2	7.6	7.6
Turbidity (NTU)	≤5	0.36	0.39	0.31	0.29	0.42	0.26	0.34	0.33	0.18	0.27
Colour – Apparent (PtCo)	≤15	0	0	0	0	0	0	0	0	0	0
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.30	0.30	0.40	0.30	0.30	0.20	0.30	0.30	0.30	0.40
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

**Remarks**

The physio-chemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water.





Denis Smith Akejo  
**Principal Quality Control Officer – KW**

*Written by:*



Enos Malambala  
**Quality Assurance Manager – KW**

*Approved by:*

	<b>National Water and Sewerage Corporation</b> Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 <sup>th</sup> March 2019	Website Report	Version No.: 1	Revision date:

**Report Date:** 23<sup>rd</sup> September 2024

**Table:** Average water quality for Kampala Water during the period running 16<sup>th</sup> September - 22<sup>nd</sup> September 2024

Parameter	National Standard For Potable Water	Monitoring Points									
		Mukono Nakapinyi PSP	Nakawa Market	Namboole Trading Center	Seeta Market	Joggo Trading Center	Kawempe Booster	Kyanja Trading Center	Komamboga Sekanyonyi zone	Ggaba Police	Nakasero Primary School
Electrical Conductivity (µs/cm)	≤1500	125	171	170	160	107	169	138	140	160	168
pH	6.5-8.5	7.7	7.7	7.7	7.6	7.3	6.9	6.9	6.8	6.7	6.9
Turbidity (NTU)	≤5	0.89	0.26	0.23	0.33	0.62	0.41	0.36	0.37	0.69	0.50
Colour – Apparent (PtCo)	≤15	5	0	0	0	0	1	0	0	4	2
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.30	0.40	0.30	0.30	0.25	0.40	0.40	0.30	0.40	0.30
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

**Remarks**

The physio-chemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water.



Denis Smith Akejo  
**Principal Quality Control Officer – KW**

Written by:



Enos Malambala  
**Quality Assurance Manager – KW**

Approved by: