
	<b>National Water and Sewerage Corporation</b> Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 <sup>th</sup> March 2019	Website Report	Version No.: 1	Revision date:

**Report Date:** 04<sup>th</sup> November 2024

**Table: Average water quality for Kampala Water during the period running 28<sup>th</sup> October - 03<sup>rd</sup> November 2024**

Parameter	National Standard For Potable Water	Monitoring Points									
		Nsambya Avemaria	Kabalagala Market	Ggaba Road Near Police	Rubaga Nabunya	Namuwongo Godown	Speke Hotel	Kinawataka Police Post	Banda Market	Bweyogerere Butto	Naalya L.C. 1
Electrical Conductivity (µs/cm)	≤1500	145	147	152	151	144	146	151	144	110	125
pH	6.5-8.5	6.8	6.8	6.8	6.6	6.7	6.6	7.1	7.0	7.0	7.1
Turbidity (NTU)	≤5	0.38	0.20	0.59	0.61	0.39	0.47	0.36	0.28	0.23	0.51
Colour – Apparent (PtCo)	≤15	1	0	3	4	3	4	3	0	0	5
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.30	0.40	0.30	0.40	0.50	0.40	0.35	0.45	0.30	0.30
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

**Remarks**

The physio-chemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water.





Denis Smith Akejo  
**Principal Quality Control Officer – KW**

Written by:



Enos Malambala  
**Quality Assurance Manager – KW**

Approved by:

	<b>National Water and Sewerage Corporation</b> Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 <sup>th</sup> March 2019	Website Report	Version No.: 1	Revision date:

**Report Date:** 04<sup>th</sup> November 2024

**Table: Average water quality for Kampala Water during the period running 28<sup>th</sup> October - 03<sup>rd</sup> November 2024**

Parameter	National Standard For Potable Water	Monitoring Points									
		Makerere College School	Kamwokya Market	Nalukolongo NEPTA	Busega Market	Buloba Trading Center	Bunamwaya Ngobe	Joggo Trading Center	Hill View Estates Sonde	Kyaliwajjala Trading Center	Kitukutwe Trading Center
Electrical Conductivity (µs/cm)	≤1500	148	148	150	152	145	154	140	126	116	114
pH	6.5-8.5	6.8	6.7	7.1	6.9	6.8	6.8	7.0	6.9	7.0	7.5
Turbidity (NTU)	≤5	0.61	0.54	0.31	0.31	0.24	0.41	0.44	0.43	0.26	0.45
Colour – Apparent (PtCo)	≤15	5	4	3	3	2	5	0	3	0	2
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.40	0.30	0.40	0.40	0.30	0.30	0.30	0.40	0.30	0.10
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

**Remarks**

The physio-chemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water.



Denis Smith Akejo  
**Principal Quality Control Officer – KW**

Written by:



Enos Malambala  
**Quality Assurance Manager – KW**

Approved by: