
	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 11th November 2024

Table: Average water quality for Kampala Water during the period running 04th November - 10th November 2024

Parameter	National Standard For Potable Water	Monitoring Points									
		Namasuba Market	Lake Victoria Serena - Mutungo	Bwaise Happy Hours	Makerere Kubiri	Mutesa I Royal University	Nakawa Market	Biina Catholic Church	Kyambogo Primary School	Nalumunye Jomayi Estates	Buddo Trading Center
Electrical Conductivity (µs/cm)	≤1500	152	157	151	155	156	117	157	155	146	159
pH	6.5-8.5	6.6	6.7	6.5	6.5	6.6	6.8	6.6	6.6	7.2	7.1
Turbidity (NTU)	≤5	0.25	0.24	0.44	0.38	0.39	0.64	0.25	0.55	0.26	0.32
Colour – Apparent (PtCo)	≤15	0	3	5	4	4	6	0	5	0	1
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.35	0.35	0.30	0.30	0.30	0.35	0.30	0.40	0.20	0.20
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physio-chemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water.





Denis Smith Akejo
Principal Quality Control Officer – KW

Written by:



Enos Malambala
Quality Assurance Manager – KW

Approved by:

	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 11th November 2024

Table: Average water quality for Kampala Water during the period running 04th November - 10th November 2024

Parameter	National Standard For Potable Water	Monitoring Points									
		Masaka Road SV	Fairway Hotel	Kyebando Kisalosalalo Zone	Kiteredde Village	Kawempe Police Station	Maganjo Nalunya	Matuga Trading Center	Mpererwe Market	Namusera Trading Center	Kabanyoro Trading Center
Electrical Conductivity ($\mu\text{s}/\text{cm}$)	≤ 1500	158	157	158	144	159	155	158	152	181	182
pH	6.5-8.5	7.0	6.6	6.7	6.6	6.9	7.2	6.8	6.7	7.0	6.5
Turbidity (NTU)	≤ 5	0.25	0.56	0.61	0.34	0.40	0.69	0.39	0.39	0.34	0.32
Colour – Apparent (PtCo)	≤ 15	0	3	5	1	4	8	6	0	0	0
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.40	0.30	0.25	0.35	0.25	0.30	0.30	0.40	0.35	0.45
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physio-chemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water.



Denis Smith Akejo
Principal Quality Control Officer – KW

Written by:



Enos Malambala
Quality Assurance Manager – KW

Approved by: