
	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 02nd December 2024

Table: Average water quality for Kampala Water during the period running 25th November - 01st December 2024

Parameter	National Standard For Potable Water	Monitoring Points									
		Mukono Health Center IV	Mukono Wakiso T/C	Namugongo Sonde	Bukerere Trading Center	Seeta Market	Kawala TC Near Police	Kansanga Market	Lakeside College Luzira	Kireka Kabaka's Palace	Namboole Stadium Hotel
Electrical Conductivity (µs/cm)	≤1500	108	120	108	108	105	149	156	110	155	154
pH	6.5-8.5	7.3	7.2	7.3	7.3	7.1	7.0	7.1	7.2	6.9	7.3
Turbidity (NTU)	≤5	0.69	0.45	0.55	0.36	0.70	0.32	0.73	0.39	0.46	0.38
Colour – Apparent (PtCo)	≤15	6	4	5	1	7	2	4	6	7	6
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.40	0.30	0.40	0.45	0.30	0.30	0.30	0.30	0.30	0.40
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physio-chemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water.





Denis Smith Akejo
Principal Quality Control Officer – KW

Written by:



Enos Malambala
Quality Assurance Manager – KW

Approved by:

	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 02nd December 2024

Table: Average water quality for Kampala Water during the period running 25th November - 01st December 2024

Parameter	National Standard For Potable Water	Monitoring Points									
		Katosi Trading Center	Ntenjeru Trading Center	Kikokiro Village	Makerere College School	Kalerwe Market Lower Wing	Bwaise Kimalimali Zone	Kawanda Trading Center	Matuga Market	Bugolobi Market	Najjera II
Electrical Conductivity ($\mu\text{s}/\text{cm}$)	≤ 1500	111	105	151	157	157	161	156	180	158	158
pH	6.5-8.5	7.4	7.4	7.0	6.6	6.6	6.8	6.9	7.4	6.9	7.0
Turbidity (NTU)	≤ 5	0.61	0.76	0.23	0.36	0.59	0.41	0.38	0.80	0.36	0.30
Colour – Apparent (PtCo)	≤ 15	6	7	1	4	9	7	0	0	6	7
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.20	0.20	0.20	0.30	0.30	0.40	0.30	0.30	0.30	0.30
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physio-chemical and bacteriological quality of the supplied water in the Network distribution complied with the National Standards for treated potable water.



Denis Smith Akejo
Principal Quality Control Officer – KW

Written by:



Enos Malambala
Quality Assurance Manager – KW

Approved by: