
	<b>National Water and Sewerage Corporation</b> Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 <sup>th</sup> March 2019	Website Report	Version No.: 1	Revision date:

**Report Date:** 24<sup>th</sup> December 2024

**Table: Average water quality for Kampala Water during the period running 23<sup>rd</sup> December - 29<sup>th</sup> December 2024**

Parameter	National Standard For Potable Water	Monitoring Points									
		Namamve Booster	Seeta Market	Bukerere Trading Center	Hill View Estates Sonde	Namugongo Sonde	Kiira Trading Center	Kyanja Trading Center	Kanyanya Kimali Zone	Namboole Stadium Hotel	Mutungo Trading Center
Electrical Conductivity (µs/cm)	≤1500	109	111	108	110	108	109	125	122	106	109
pH	6.5-8.5	7.3	7.2	7.3	7.3	7.3	7.4	7.6	7.0	7.3	7.3
Turbidity (NTU)	≤5	0.41	0.49	0.31	0.44	0.39	0.45	0.77	0.76	0.31	0.42
Colour – Apparent (PtCo)	≤15	8	7	6	7	5	8	7	7	5	6
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.50	0.30	0.45	0.40	0.30	0.30	0.25	0.30	0.30	0.30
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

**Remarks**

The physico-chemical and bacteriological quality of the supplied water within the distribution network complied with the National Standards for Treated Potable Water. Therefore, the water is safe for consumption.





Denis Smith Akejo  
**Principal Quality Control Officer – KW**

Written by:



Enos Malambala  
**Quality Assurance Manager – KW**

Approved by:

	<b>National Water and Sewerage Corporation</b> Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 <sup>th</sup> March 2019	Website Report	Version No.: 1	Revision date:

**Report Date:** 24<sup>th</sup> December 2024

**Table: Average water quality for Kampala Water during the period running 23<sup>rd</sup> December - 29<sup>th</sup> December 2024**

Parameter	National Standard For Potable Water	Monitoring Points									
		Butabika Hospital	Lakeside College Luzira	Bwaise Kimalimali Zone	Kalerwe Market Upper Wing	Makerere College School	Banda Market	Bugolobi Market	Lugogo Bypass	Bukoto White Flats	Ntenjeru Trading Center
Electrical Conductivity (µs/cm)	≤1500	110	152	145	145	144	149	148	151	135	94
pH	6.5-8.5	7.3	6.8	7.9	7.9	7.4	6.9	6.7	7.2	6.8	7.3
Turbidity (NTU)	≤5	0.44	0.56	0.49	0.32	0.27	0.49	0.45	0.55	0.67	0.34
Colour – Apparent (PtCo)	≤15	4	5	5	1	0	4	4	5	6	1
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.20	0.30	0.30	0.35	0.35	0.40	0.30	0.40	0.30	0.25
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

**Remarks**

The physico-chemical and bacteriological quality of the supplied water within the distribution network complied with the National Standards for Treated Potable Water. Therefore, the water is safe for consumption.



Denis Smith Akejo  
**Principal Quality Control Officer – KW**

Written by:



Enos Malambala  
**Quality Assurance Manager – KW**

Approved by: