
	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 06th January 2025

Table: Average water quality for Kampala Water during the period running 30th Dec 2024 - 05th Jan 2025

Parameter	National Standard For Potable Water	Monitoring Points									
		Mukono UCU	Mukono Nama Trading Center	Seeta Bajjo Trading Center	Mengo Bulange	Kisenyi III Kiguli Zone	Nakulabye Market	Kisaasi Trading Center	Kungu Trading Center	Kinawataka Police Post	Kasengejje Road
Electrical Conductivity (µs/cm)	≤1500	113	106	107	159	159	159	129	130	153	157
pH	6.5-8.5	7.4	7.4	7.5	7.0	7.0	7.0	7.2	7.1	6.8	6.9
Turbidity (NTU)	≤5	0.66	0.39	0.59	0.52	0.45	0.50	0.51	0.36	0.39	0.32
Colour – Apparent (PtCo)	≤15	4	4	5	5	4	4	7	4	6	3
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.40	0.30	0.40	0.40	0.20	0.40	0.30	0.30	0.30	0.20
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physico-chemical and bacteriological quality of the supplied water within the distribution network complied with the National Standards for Treated Potable Water. Therefore, the water is safe for consumption.





Denis Smith Akejo
Principal Quality Control Officer – KW

Written by:



Enos Malambala
Quality Assurance Manager – KW

Approved by:

	National Water and Sewerage Corporation Ggaba Laboratory	Document No.: NWSC/WPD/QF/21.4	
Effective date: 19 th March 2019	Website Report	Version No.: 1	Revision date:

Report Date: 06th January 2025

Table: Average water quality for Kampala Water during the period running 30th Dec 2024 - 05th Jan 2025

Parameter	National Standard For Potable Water	Monitoring Points									
		Namuwongo Market	Aqua Coolers Ltd - 7th Street	Makindye Washing Bay	Salaama Road	Twinbrook Kindergaten Bamba	Kasangati Market	Matuga Trading Center	Bugolobi Market	Kiswa Health Center	Katosi Trading Center
Electrical Conductivity ($\mu\text{s}/\text{cm}$)	≤ 1500	159	165	160	164	109	108	108	133	163	95
pH	6.5-8.5	6.8	6.9	6.8	7.5	7.2	7.3	6.8	7.1	7.0	7.3
Turbidity (NTU)	≤ 5	0.41	0.45	0.58	0.20	0.76	0.38	0.65	0.43	0.52	0.36
Colour – Apparent (PtCo)	≤ 15	4	4	5	0	7	3	6	4	5	1
Escherichia Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Faecal Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Total Coliforms (CFU/100m/L)	0	0	0	0	0	0	0	0	0	0	0
Residual Chlorine (mg/L)	0.20-0.50	0.40	0.30	0.20	0.30	0.20	0.30	0.35	0.30	0.30	0.25
Total Suspended Solids (mg/L)	0	0	0	0	0	0	0	0	0	0	0

Remarks

The physico-chemical and bacteriological quality of the supplied water within the distribution network complied with the National Standards for Treated Potable Water. Therefore, the water is safe for consumption.



Denis Smith Akejo
Principal Quality Control Officer – KW

Written by:



Enos Malambala
Quality Assurance Manager – KW

Approved by: